
Design No. CEJ 123P


PERIMETER FIRE BARRIER SYSTEM

T-Rating - 1/4 hr.

F-Rating - 2 hr.

L-Rating <1 SCFM/LF

Rated for $\pm 16.7\%$ movement



1. **CONCRETE FLOOR ASSEMBLY:** Two-hour rated concrete floor assembly made from either lightweight or normal weight concrete with a density of 100-150 pcf, with a min. thickness of 4-1/2-in. at the joint face. Overall slab thickness may vary to accommodate various blockout depths (longitudinal recesses) formed in the concrete, to house the architectural cover plate. The blockout width may also vary without restriction.
2. **CURTAIN WALL ASSEMBLY:** The curtain wall assembly shall incorporate the following construction features:
 - A. **Mounting Attachment:** (Not shown) Attachment of the curtain wall framing to the structural framing shall be according to the curtain wall manufacturer's instructions. When required, the mounting attachments to the floor slab shall be connected to the joint face of the floor slab, according to the curtain wall manufacturer's instructions. Max. distance between mounting attachments shall be 10 feet.
 - B. **Steel-Stud Framing:** Vertical framing members shall be min. 5-1/2 in. by 1-5/8 in., 18 GA steel "C" studs. Attachment shall be according to the curtain wall

system manufacturer's guidelines. Vertical framing not to exceed a spacing of 48 in. o.c. Horizontal framing members not to exceed 72 in. o.c.

- C. Glass Panels: Glass panels shall be installed to curtain wall framing according to the curtain wall system manufacturer's guidelines. Use a min. 1/4 in. thick, clear heat-strengthened (HS) or tempered glass with a max. width of 48 in.
- D. Impaling Pins: When used with insulation and framing covers, the pins shall be located, sized and installed according to the curtain wall system manufacturer's guidelines, or be a min. 4-1/2 in. long, 12 GA steel pin attached to a nom. 2 in. by 2 in. galvanized sheet steel plate, a nom. 2 by 2 by 2 in. long angle, or directly attached to steel panel using a stud gun. Pins shall be spaced a max. of 12 in. o.c. and installed around the periphery (min.) so that the interior face of the curtain wall insulation is flush with the interior face of the framing.
- E. Curtain Wall Insulation: A nom. 4 in. thick, 4 pcf mineral wool batt insulation faced on one side with aluminum foil scrim (vapor retarder) which is exposed to the room interior and installed the stud cavity. Batts are fitted tightly between vertical framing members secured with clips, impaling pins, or friction fit using a batt insulation length at least 1/4 in. longer than the distance between vertical framing members. All meeting edges of insulation are sealed with nom. 4-in. wide pressure sensitive aluminum foil faced tape centered over the junction so that approx. 2 in. of tape covers each edge of the adjacent insulation. The nom. 4-in. wide pressure sensitive aluminum foil faced tape is applied over all meeting edges of insulation and framing members so that approx. 2 in. of tape covers each edge of the adjacent material. In lieu of filling the full depth of the stud cavity with 4 pcf mineral wool, the use of 2 in. 8 pcf mineral wool is allowed but may not be secured by friction fit and must have a horizontal support angle installed at the mid depth of the perimeter joint protection and mechanically attached to all vertical framing. The interior face of the batts, if required compressed, flush

with the interior face of the curtain wall framing. A min. 1-1/4-in. air space is created between the insulation and panel. The 24 in. wide batts shall be installed without vertical seams, spanning the full length between the vertical curtain wall framing members. Batt insulation shall fill the cavity of all "C"-shaped studs. Horizontal seams in the insulation are to be at least 6 in. from the top surface of the perimeter joint treatment.

- F. Framing Covers: Strips made of 1 in. thick by 4 in. wide, 8 pcf, mineral wool batt insulation faced on one side with aluminum foil scrim (vapor retarder) which is exposed to the room interior. Framing covers are centered over each vertical framing member and secured to the member with impaling pins and clips spaced at least 12 in. o.c. and attached in accord with 2d. Framing covers do not pass through the perimeter joint treatment. They are butted to the top and bottom surfaces of the perimeter joint treatment.
- 3. PERIMETER JOINT PROTECTION: The perimeter joint (linear opening) shall not exceed an 8 in. nom. joint width (joint width at installation) and the perimeter joint treatment shall incorporate the following construction features:
 - A. Packing Material: Use a min. 4 in. thick, 4 pcf density, mineral wool batt insulation installed with the fibers running parallel to the slab edge and curtain wall. The packing material shall be compressed 50% in the nominal joint width. Compress the batt insulation into the perimeter joint such that the top surface of the batt insulation is flush with the top surface of the concrete floor slab. Splices (butt joints) in the lengths of mineral wool batt insulation are to be tightly compressed together. Reference the Introduction to Fire Resistive Joint Systems Section of this Directory for more details on how to determine the cut width of the insulation to be installed in the nominal joint width, and how to determine the compressed percentage of a known insulation width installed in a known nominal joint width.
 - B. Fill, Void or Cavity Material: Liquid is to be spray applied to cover the exposed surface of the mineral wool installed in

the perimeter joint. Apply a min. wet film thickness of 1/8 in. and overlap the material a min. 1/2 in. onto the adjacent curtain wall assembly and concrete floor slab assembly. If the spraying process is stopped and the applied liquid cures to an elastomeric film before process is restarted, then overlap the edge of the cured material at least 1/8 in. with the spray. Reference Product Section of this Directory for more details about the Listed product.

Listed Manufacturer:

3M --

Joint Sealant

Spray

FireDam™ Spray 100

- C. Support Clips: (Not Shown) Support clips are optional but recommended for installations subject to vertical shear movement. Standard Z-shaped clips are 20 GA galvanized steel with the following dimensions: 1 in. wide by 3 in. high with a 2 in. upper leg and 3 in. lower leg.