

Grabber Construction Products, Inc. Design No. JWA/PHV 120-16


Horizontal (Floor/Ceiling) or Vertical (Wall) Assembly, Single Penetrations GrabberGard EFC and GrabberGard IFC


Test Standards: ASTM E814, UL 1479, ULC S115: Non-metallic Open and Closed Systems Positive Pressure Differential – 50 Pa (0.2 in. of water) Minimum


Rating: 2 Hour


Penetrating Item Material	Nominal Pipe Size	Annular Space	Layers of Wrap Strip	ASTM E814/ UL1479 "F" Rating	ASTM E814/ UL1479 "T" Rating	CAN/ULC S115	
						"F" & "FH" Rating	"FTH" Rating
PEX Pipe	Up to 2 in. ID	1/4 in.	2	Up to 2 hours	1/4 Hour	Up to 2 Hours	1/4 Hour
PE/PE-RT Pipe	Up to 2 in. ID	1/4 in.	2	Up to 2 hours	1/4 Hour	Up to 2 Hours	1/4 Hour
PVC Pipe	Up to 2 in.	1/8 in.	1	Up to 2 Hours	3/4 Hour	Up to 2 Hours	3/4 Hour
PVC Pipe	< 2 in. to 3 in.	1/4 in.	2	Up to 2 Hours	2 Hours	Up to 2 Hours	2 Hours
PVC Pipe	<3 in. to 4 in.	3/8 in.	3	Up to 2 Hours	2 Hours	Up to 2 Hours	2 Hours
ccPVC Pipe	Up to 2 in.	1/8 in.	1	Up to 2 Hours	2 Hours	Up to 2 Hours	2 Hours
ccPVC Pipe	< 2 in. to 3 in.	1/4 in.	2	Up to 2 Hours	2 Hours	Up to 2 Hours	2 Hours
ccPVC Pipe	<3 in. to 4 in.	3/8 in.	3	Up to 2 Hours	2 Hours	Up to 2 Hours	2 Hours
CPVC Pipe	Up to 2 in.	1/8 in.	1	Up to 2 Hours	2 Hours	Up to 2 Hours	2 Hours
CPVC Pipe	< 2 in. to 3 in.	1/4 in.	2	Up to 2 Hours	2 Hours	Up to 2 Hours	2 Hours
CPVC Pipe	<3 in. to 4 in.	3/8 in.	3	Up to 2 Hours	2 Hours	Up to 2 Hours	2 Hours
ABS Pipe	Up to 2 in.	1/8 in.	1	Up to 2 Hours	2 Hours	Up to 2 Hours	2 Hours
ABS Pipe	< 2 in. to 3 in.	1/4 in.	2	Up to 2 Hours	2 Hours	Up to 2 Hours	2 Hours
ABS Pipe	<3 in. to 4 in.	3/8 in.	3	Up to 2 Hours	2 Hours	Up to 2 Hours	2 Hours
FRPP Pipe**	Up to 2 in.	1/8 in.	1	Up to 2 Hours	2 Hours	Up to 2 Hours	2 Hours

^{**}Not tested through concrete fluted steel deck floor assembly









- **1. PENETRATING ITEM:** Centered in hole, See table above. Single penetrations only.
- 2. FLOOR/CEILING OR WALL ASSEMBLY: Use a floor/ceiling or wall assembly with a fire resistance rating determined in accordance with ASTM E119,

UL 263, or CAN/ULC-S101, as applicable. The floor/ceiling or wall assembly fire rating shall be equal to or greater than the "F" rating of the through-penetration firestop assembly, and shall comply with the following min. requirements:

Date Revised: August 8, 2018 Page 1 of 2 Project No. 491-8282



Division 07 – Thermal and Moisture Protection 07 84 00 Firestopping 07 84 13 Penetration Firestopping

- a) Cast-in-place, normal or light density concrete floor/ceiling assemblies having a min. thickness of 4-1/2 in. (113mm).
- b) Cast-in-place concrete wall assemblies having a min. cross-section thickness of 4-1/2 in. (113mm) or;
- c) Hollow or concrete filled unit masonry (concrete block) wall assemblies laid up with mortar, having a min. cross-section thickness of 8 in. (200mm).
- d) Min. 20 GA or heavier galvanized steel decking with min. 1-1/2 in. (38mm) flute height firmly supported, with min. 3 in. (75mm) concrete cover.
- **3. FIRESTOP SYSTEM COMPONENT 1:** Grabber Construction Products, Inc. GrabberGard EFC* or GrabberGard IFC* installed at a min. thickness of 1/4 in. (6mm) within the annulus at top surface

- of floor assembly. A min. of 1/2 in. (13mm) bead of GrabberGard EFC* or GrabberGard IFC* is to be applied between interface of the floor or wall and the outer layer of intumescent wrap strip (see Firestop System Component 2). **Note:** For PE (Polyethylene Pipe) use only GrabberGard IFC*.
- **4. FIRESTOP SYSTEM COMPONENT 2:** PFP Partners WS1 Wrap Strip* Nominal 1/8 in. thick intumescent material supplied in 2 in. (50mm) wide strips. See table for number of layers of wrap strip friction fitted into annular space. Wrap strip to extend max. 1/4 in. (6mm) below the bottom surface of the floor or both sides of the wall and fastened in place with aluminum tape.
 - *WH Labeled Component

Version: 02 August 2017 SFT-BC-OP-19i