

Certificate of Compliance



You have been awarded:

Intertek Warnock Hersey Mark for Fire Resistant Door and Frame Assemblies

UBC 7-2 (1997), ASTM E2074 (2004), UL 10(b) (2008), UL 10(c) (2009), CAN / ULC S104 (2010), NFPA 252 (2012), CAN / ULC S104 (2015)

Certificate number: WHI19 – 31837715

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

Organization:

Aberdeen Door Company LLC
3778 NW 124th Avenue
Coral Springs, FL 33065
USA

Product: Warm Springs 20-90 Min Fire Door Frame
SPEC ID: 14775

For Maximum Sizes and Ratings See Appendix A (Pages 2 of 2)

Certification body: Intertek Testing Services NA, Inc.
Initial registration: February 25, 2019
Date of expiry: February 25, 2024
Issue status: 1

Charles Meyers
Certification Manager

A handwritten signature in black ink, appearing to read 'C. Meyers'.

Name

Signature

2/25/19
Date

www.intertek.com

Registered address:
Intertek Testing Services NA, Inc. 545 E. Algonquin Rd. Arlington Heights, IL 60005 USA

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Certificate of Compliance WHI19 – 31837715

Appendix A

Category C - Proprietary Frames

Composite Door frame for Installation in 20, 45, 60, or 90 Minute locations in steel/wood stud drywall or masonry openings. A Category B or Neutral Pressure fire rated wood/composite door may be used depending on the application. Category G Edge Sealing System is not required for the frame. May be veneered or faced with HPL. Frame may also be used as a communicating frame, and for fixed panel sidelites and transoms.

LIMITATIONS

Composite Frame Leg

RATING	CONFIGURATION	MAX. OVERALL OPENING	MIN. WALL THICKNESS
20 Min. 45 Min. 60 Min. 90 Min.	Single Swing	4 ft. 0 in. wide 8 ft. 0 in. high	4-1/2 in.
	Pairs	8 ft. 0 in. wide 8 ft. 0 in. high	4-1/2 in.

MDF or Anti-Fire Composite Frame Leg

RATING	CONFIGURATION	MAX. OVERALL OPENING	MIN. WALL THICKNESS
20 Min. 45 Min. 60 Min.	Single Swing	4 ft. 0 in. wide 8 ft. 0 in. high	4-1/2 in.
20 Min.	Pairs	7 ft. 0 in. wide 8 ft. 0 in. high	4-1/2 in.

Wood Frame Leg

RATING	CONFIGURATION	MAX. OVERALL OPENING	MIN. WALL THICKNESS
20 Min. 45 Min.	Single Swing	4 ft. 0 in. wide 8 ft. 0 in. high	4-1/2 in.

Each frame option noted above must be constructed in accordance with the specifications of the Manufacturing section of the Listing report.