

Certificate of Compliance



You have been awarded:

Intertek Warnock Hersey Mark for Fire Resistant Door and Frame Assemblies

UL 10(c) (2009), UL 10(b) (2009), CAN / ULC S104 (2010), NFPA 252 (2012), UL 10(c) (R2015), CAN / ULC S104 (2015)

Certificate number: WHI19 – 31837709

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

Organization:

Aberdeen Door Company LLC
3778 NW 124th Avenue
Coral Springs, FL 33065
USA

Product: Lexington Fire Shield 90 Min. Flush Fire Door SPEC ID: 45357

For Maximum Sizes and Ratings See Appendix A (Pages 2-3)

Certification body: Intertek Testing Services NA, Inc.
Initial registration: February 25, 2019
Date of expiry: February 25, 2024
Issue status: 1

Charles Meyers
Certification Manager

Name

Signature

2/25/19
Date

www.intertek.com

Registered address:

Intertek Testing Services NA, Inc. 545 E. Algonquin Rd. Arlington Heights, IL 60005 USA

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Certificate of Compliance WHI19 – 31837709

Appendix A

FIRE RESISTANT PRODUCTS & COMPONENTS

CATEGORY A DOORS - NO ADDITIONAL EDGE-SEALING SYSTEM REQUIRED Category "A" Wood Composite Core, swinging door for use in 20 through 90-minute positive pressure assemblies (also eligible for use in neutral pressure assemblies).

CATEGORY B DOORS - ADDITIONAL EDGE-SEALING SYSTEM REQUIRED Category "B" Wood Composite Core, swinging door for use in 20 through 90-minute positive pressure assemblies (also eligible for use in neutral pressure assemblies). A surface applied Category G intumescent edge seal system is required.

PRODUCT COVERED

Lexington Fire Shield 90 Min. Flush Fire Door

PRODUCT DESCRIPTION

Hardware Limitations: Cylindrical / Cylindrical with Deadbolt / Mortise / Card Reader / Surface-Mounted Vertical Rod Fire Exit Devices / Rim-Type Surface Mounted Fire Exit Devices / Surface Bolts or Mortised Flush Bolts / Surface Mounted or Concealed Door Bottoms / Surface Mounted or Concealed Closers or Overhead Stops / Viewer / Vision Kit - Max. 960 sq. in./ 860 sq. in temp rise glazing/ 2176 sq. in. 45 minute / Raceway / EPT / Plant-Ons / Protection Plates / Reveals and Inlays.

Configuration	Maximum Size
----------------------	---------------------

<i>Single</i>	4'0" wide x 9'0" high
<i>Standard Pair</i>	8'0" wide x 8'0" high* 6'0" wide by 9'0" high*
<i>Double Egress</i>	8'0" wide x 8'0" high*

* See table and comments below

Certificate of Compliance WHI19 – 31837709

Appendix A

Duration (minutes)	Maximum size (w x h)	Swing	Latching	Metal Edge (5")	Comments
90	8'0" by 8'0"	Std Pair	SVR 4 Pt.	No	None
90	8'0" by 8'0"	Std Pair	3 Pt. latching Auto or manual flushbolts	No	Cylindrical or Mortise minimum 1/2" throw
90	8'0" by 8'0"	Double Egress	SVR 4 pt.	No	Must have top and bottom rod Hardware secured with sexbolts
90	8'0" by 8'0"	Double Egress	CVR/CVC 2 pt.	Yes	Requires thermal pin door to door
90	8'0" by 7'0"	Double Egress	CVR / SVR 2 pt.	Yes	No pin
90	6'0" by 9'0"	Std. Pair	CVR 4 pt.	Yes	Bottom latches required.
90	8'0" by 7'0"	Std. Pair	CVR 2 pt.	Yes	No

These doors are eligible for use in any "Category C - Standard" frame. These doors may also be installed in frames listed in "Category C - Proprietary" in the accordance with the frame manufacturer's individual listing.

The door noted above is eligible to bear the "S" (for Smoke & Draft Control assemblies) if a listed "Category H - Smoke & Draft Control Gasket" has been applied to the assembly. Please refer to Category H for individual gasket manufacturer's listings.