

Certificate of Compliance



You have been awarded:

Intertek Warnock Hersey Mark for Fire Resistant Door and Frame Assemblies

UBC 7-2 (1997), UBC 7-2 (1994), UL 10(b) Revision 1 (2009), UL 10(c) (2009), CAN / ULC S104 (2010), NFPA 252 (2012), CAN / ULC S104 (2015), UL 10(c) (2016), NFPA 252 (2017)

Certificate number: WHI19 – 31837714

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

Organization:

Aberdeen Door Company LLC
3778 NW 124th Avenue
Coral Springs, FL 33065
USA

Product: Lexington Fire Fiber 20L & 20A Fire Door
SPEC ID: 29726

For Maximum Sizes and Ratings See Appendix A (Pages 2 of 2)

Certification body: Intertek Testing Services NA, Inc.
Initial registration: March 4, 2019
Date of expiry: February 25, 2024
Issue status: 2

Charles Meyers
Certification Manager

A handwritten signature in black ink, appearing to read 'Charles Meyers'.

3/4/19

Name

Signature

Date

www.intertek.com

Registered address:
Intertek Testing Services NA, Inc. 545 E. Algonquin Rd. Arlington Heights, IL 60005 USA

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Certificate of Compliance WHI19 – 31837714

Appendix A

PRODUCT COVERED

Lexington 20 Minute Rated Agri Composite Core Fire Doors (20L=20#, 20A=27#). Single swing, Standard Pairs and Double Egress (flush) doors for installation in up to 20-minute locations. Any listed wood, aluminum, or steel frames may be used as per frame manufacturer's listing(s).

PRODUCT DESCRIPTION

Maximum Sizes

Single-Swing	4'0" x 9'0"
Standard Pairs	8'0" x 9'0"
Double Egress Pairs	8'0" x 9'0"
Temperature Rise	Max. 250°F @ 20 mins.

LIMITATIONS

Hardware – Cylindrical or mortise locks, card locks, surface mount hardware, concealed vertical rod fire exit hardware, rim exit hardware, concealed closer, concealed door stop, mortise automatic door bottoms, maximum 1296 sq. in. lites, 48 in. x 48 in. maximum surface plates, viewers, louvers installed below latch level, automatic flushbolts, mortise exit devices, raceways, electric power transfers, edge guards, lay-on or applied molding, pivot and continuous hinges.

Doors constructed as described in this procedure meet the requirements for both positive and neutral pressure fire tests, UL 10(c), UBC 7-2 (1997) Part 1, NFPA 252, CAN/ULC S104, UBC 7-2 (1994), and UL 10 (b).

These doors are Category "A" doors (no additional edge sealing system is required).

Doors labeled for positive pressure applications must include installation instructions to be furnished by the door labeler. Unless otherwise noted in the door's installation instructions all intumescent materials and smoke/draft control gasketing used in the assembly are to be installed per their respective manufacturer's instructions.

These assemblies are eligible for Category B - Doors - Additional Edge-Sealing System Required

This category includes doors evaluated with an edge-sealing system (Category G) field-applied to the labeled frame or door. The application of the edge-sealing system does not require any machining of the frame or door. Please refer to "Category G - Edge-Sealing System" for individual manufacturer's listings.

These assemblies are eligible for use in any "Category C - Standard" frame. These doors may also be installed in frames listed in "Category C - Proprietary" in the accordance with the frame manufacturer's individual listing. All doors listed in Category B are eligible to bear the "S" (for Smoke & Draft Control assemblies) if a listed "Category H - Smoke & Draft Control Gasket" has been applied to the assembly. Please refer to Category H for individual gasket manufacturer's listings.

www.intertek.com