
DESIGN NO. TRC/PH 60-02 HORIZONTAL (FLOOR), F & T RATING - 1 HR; ANNULAR SPACING - 1/8" MAX. TEST PRESSURE DIFFERENTIAL - 2.5 Pa (0.01" OF WATER) MINIMUM



Manufacturer's Designation: 950 WF-18.

- 1. Floor: Minimum 11-21/32" thick wood floor/ceiling construction (UL Design No. L511).
 - a) 11/16" Wood Decking or 3/4" Gypcrete with a 1/2" diameter opening.
 - b) Two 5/8" Gypsum Wall Board spaced 1/2" apart with a 1/2" diameter opening.
 - c) 2 x 10 Wood Stud.
- 2 Penetrations: One (1) Telephone Cable consisting of 25 paired insulated telephone wires.
- 3. Caulking Compound or Filler Material:
 - a) 1-3/8" Metalines, Inc. Metacaulk* 950 at floor.
 - b) 5/8" Metalines, Inc. Metacaulk* 950 at ceiling.

^{*}Component bearing the Warnock Hersey Certification Mark