

1. Wall: Nominal 5" thick steel or wood stud fire rated gypsum drywall partitions; concrete block or concrete with a 1/2" diameter opening.
2. Penetrations: 1) 1 Telephone Cable consisting of 25 paired insulated telephone wires.
3. Caulking Compound or Filler Material: Maximum extent Metalines, Inc. Metacaulk* 950 each side of partition.

*Component bearing the Warnock Hersey Certification Mark