
## DESIGN NO. TRC/PV 120-07 VERTICAL (WALL), F RATING - 2 HRS, T RATING - 1-1/2 HRS; ANNULAR SPACING - 1/8" MAX. TEST PRESSURE DIFFERENTIAL - 2.5 Pa (0.01" OF WATER) MINIMUM



Manufacturer's Designation: 950 GW-4.

- 1. Wall: Nominal 5" thick steel or wood stud fire rated gypsum drywall partitions; concrete block or concrete with a 1/2" diameter opening.
- 2. Penetrations: 1) 1 Telephone Cable consisting of 25 paired insulated telephone wires.
- 3. Caulking Compound or Filler Material: Maximum extent Metalines, Inc. Metacaulk\* 950 each side of partition.

<sup>\*</sup>Component bearing the Warnock Hersey Certification Mark