

3M Company
Design No. 3M/PV 120-06
Through Penetration
3M™ FireStrap™
3M™ Fireplug™
3M™ FireDam FD-150+
3M™ Fire Barrier IC 15WB+
3M™ Fire Barrier CP 25WB+
3M™ Fire Barrier 3000WT
CAN/ULC-S115
Rating: See Table 1
Pressure Differential: Positive, 50 Pa (0.20 in. w.g.)

TABLE 1. RATINGS

		CAN/ULC-S115
Penetrating Item	Max. Pipe Size	F, FT, FH, FTH
PVC	2 in.	1 & 2 Hr
System XFR	2 in.	1 & 2 Hr




Figure 1. Penetration Detail



1. **WALL ASSEMBLY:** Code confirming 1- or 2-hour fire-rated wall, nominal 2x4 steel or wood framed gypsum wallboard wall assembly.
2. **PENETRATING ITEMS:** (See Table 1) Schedule 40, PVC and System XFR pipes for use in DWV (Drain, Waste, and Vent) or Closed (Process and Supply) piping systems. Ratings achieved will equal that of the wall assembly (Item 1).
3. **FIRESTOP SYSTEM COMPONENTS:**

Pipe Size	Opening Diameter
1-1/2 in.	3 in.
2 in.	3 in.

a) Certified Products:

- **3M™ FireStrap™**
- **3M™ Fireplug™**

Install with 1/4-in. of the firestop exposed outside the surface of the gypsum wall assembly according to the manufacturer's instructions.

b) Certified Products: Sealant

- **3M™ FireDam FD-150+**
- **3M™ Fire Barrier IC 15WB+**
- **3M™ Fire Barrier CP 25WB+**
- **3M™ Fire Barrier 3000WT**

Seal the annular space between the opening and the firestop device, to 1/4-in. thickness, flush with the wall surface on both sides of the wall.

Consult the listing report on the Directory of Building Products (<https://bpdirectory.intertek.com>) for the edition of the standard(s) evaluated.

Compliance of the assembly described in this Design Listing with the referenced standard relies on verification that the assembly constructed in the field is consistent with that described herein. Intertek certified products may be verified by the approved Intertek label; other products must be verified by the Authority Having Jurisdiction as meeting the specifications stated herein.