

# Product Certification Listing

CERTIFIED BY INTERTEK



## PCL – 0901

Issue Date: July 15, 2022

Revision Date: July 20, 2023

**Company:** Style Crest, Inc.  
2450 Enterprise Street  
Fremont, Ohio 43420  
[www.stylecrest.net](http://www.stylecrest.net)

HOMEX, MBS Polaris, RMC Siding, and Style Crest Vinyl Siding products are extruded, rigid PVC siding conforming to ASTM D3679, as exterior wall covering

### 1. LISTING

**Listing Ref:** Intertek Spec ID: 68575  
**Category:** Vinyl Siding  
**CSI Section:** 07 46 33 Plastic Siding

**Standards:** ASTM D3679-21 Standard Specification for Rigid Poly (Vinyl Chloride) (PVC) Siding

**Certification Scheme:** VSI Product Certification Program  
Vinyl Siding Institute, Inc.

### 2. PRODUCTS

#### Certified Products and Standard Design Pressure Rating

Brand	Product	Style	Design Pressure (PSF)
HOMEX	Addison Heights	Double 4 <sup>(1)</sup>	53
		Double 4.5 Dutchlap <sup>(1)</sup>	53
		Double 5 Dutchlap <sup>(1)</sup>	53
	Alpine Ridge	Double 4 <sup>(1)</sup>	53
		Double 4 Dutchlap <sup>(1)</sup>	53
		Double 5 Dutchlap <sup>(1)</sup>	53
	Bristol Bay	Double 4 <sup>(1)</sup>	53
		Double 4.5 Dutchlap <sup>(1)</sup>	53
		Double 5 <sup>(1)</sup>	53
		Double 5 Dutchlap <sup>(1)</sup>	53
	Lexington Series	Board & Batten <sup>(2)</sup>	82
		Beaded 6.5 <sup>(1)</sup>	45
ProPride	Double 4.5 Dutchlap <sup>(1)</sup>	49	
MBS Polaris	UltraSide	Double 4 <sup>(1)</sup>	56
		Double 4.5 Dutchlap <sup>(1)</sup>	56

# Product Certification Listing

CERTIFIED BY INTERTEK



## PCL – 0901

Issue Date: July 15, 2022

Revision Date: July 15, 2022

### Certified Products and Standard Design Pressure Rating

Brand	Product	Style	Design Pressure (PSF)
RMC Siding	Fairfield	Double 4 <sup>(1)</sup>	53
		Double 4 Dutchlap <sup>(1)</sup>	53
		Double 5 Dutchlap <sup>(1)</sup>	53
	Oak Harbor	Double 4 <sup>(1)</sup>	53
		Double 4.5 Dutchlap <sup>(1)</sup>	53
		Double 5 <sup>(1)</sup>	53
		Double 5 Dutchlap <sup>(1)</sup>	53
	ProPride	Double 4.5 Dutchlap <sup>(1)</sup>	49
	Select Series	Board & Batten <sup>(2)</sup>	82
		Beaded 6.5 <sup>(1)</sup>	45
	Spiegel Grove	Double 4 <sup>(1)</sup>	53
		Double 4.5 Dutchlap <sup>(1)</sup>	53
Double 5 Dutchlap <sup>(1)</sup>		53	
Style Crest Siding	Board & Batten	Board & Batten <sup>(2)</sup>	82
	Carrington Collection	Double 4 <sup>(1)</sup>	56
		Double 4.5 Dutchlap <sup>(1)</sup>	56
	Sawmill	Double 4 <sup>(1)</sup>	53
		Double 5 Dutchlap <sup>(1)</sup>	53
		Triple 3.33 <sup>(1)</sup>	53
	Town Square	Double 4 <sup>(1)</sup>	53
		Double 5 <sup>(1)</sup>	53
		Double 5 Dutchlap <sup>(1)</sup>	53

- (1) Standard design pressure rating is the maximum allowable negative wind load when installed horizontally with 1-1/2-inch long, 1/8-inch shank diameter nail with a 7/16-inch head diameter. Spacing shall be 16 inches o.c. for horizontal siding and penetrating wood framing.
- (2) Standard design pressure rating is the maximum allowable negative wind load when installed vertically with 1-1/4-inch long, 1/8-inch shank diameter nail with a 7/16-inch head diameter. Spacing shall be 12 inches o.c. for vertical siding and penetrating 7/16-inch OSB or plywood sheathing.

# Product Certification Listing

CERTIFIED BY INTERTEK



## PCL – 0901

Issue Date: July 15, 2022

Revision Date: July 15, 2022

**Identification:** Products covered by this listing are identified with labels that include the following:

**Style Crest, Inc.**  
**Production lot identification**  
**VSI certification mark**  
**Product Certification Listing (PCL) No, standards and related ratings**

**Certified By Intertek:**  
ASTM D3679  
Std Design Pressure Rating:  
## PSF (ASD)



CERTIFICATION PROGRAM

**PCL-0901**

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name, one of its marks or the VSI mark for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.