


Pacific Woodtech Corporation
Design No. PWT/RB 120-01
Rim Board
PWT Rim Board
ASTM E119
Rating: 2-hour



1. Upper-Level Framing: Continuous or Non-continuous roof/ceiling or floor/ceiling assembly

2. Floor /Ceiling Assembly: Minimum 1-hour rated.

3. RIM BOARD

CERTIFIED PRODUCT: Pacific Woodtech Corporation. PWT Rim Board

A. Min. 1 in. thick PWT Rim Board

B. Direct-applied protection continuous gypsum wallboard at occupancy side attached to rim board using Type W screws at 12 in. on center (oc).

- 5/8 in. Type X attached using 1-1/2 in. long screws.
- Min. 2-layers, 1/2 in. Type X attached using min. 2 in. long screws.

4. Wall Assembly: Min. 2-hour rated.