


Pacific Woodtech Corporation
Design No. PWT/RB 60-01
Rim Board
PWT Rim Board
ASTM E119
Rating: 1 Hour



- **1. UPPER-LEVEL FRAMING:** Non-continuous roof/ceiling or floor/ceiling assembly
- **2. FLOOR/CEILING ASSEMBLY:** Unrated, 45 min. rated, or 1-hour rated.
- 3. RIM BOARD

CERTIFIED PRODUCT: Pacific Woodtech Corporation, PWT Rim Board

A. Min. 1 in. thick PWT Rim Board

- B. Direct-applied protection continuous gypsum wallboard attached to rim board with 1-1/2 in. Type W screws at 12 in. on center (oc)
 - 5/8 in. Type X at occupancy sides required when item 2. is unrated.
 - 1/2 in. conventional at occupancy sides required when item 2. is 45 min. rated.
 - Not required when item 2. is 1-hour rated.
- 4. WALL ASSEMBLY: Min. 1 hour rated.