




Pacific Woodtech Corporation
Design No. PWT/RB 60-02
Rim Board
PWT Rim Board
ASTM E119
Rating: 1 -hour



- **1. Upper-Level Framing:** Continuous roof/ceiling or floor/ceiling assembly.
- 2. Floor/ceiling Assembly: Unrated.
- 3. RIM BOARD

CERTIFIED PRODUCT: Pacific Woodtech Corporation. PWT Rim Board

- A. Min. 1-1/4-in. thick PWT Rim Board
- B. Direct-applied protection continuous gypsum wallboard attached to rim board with 1-1/2-in. Type W screws at 12 in. on center (oc):

- 1/2-in. Type X at occupancy one cavity side is required when Floor/Ceiling Assembly (Item 2) is unrated with gypsum board joints taped and filled.
- 1/2-in. conventional at each cavity or occupancy sides required when Floor/Ceiling Assembly (Item 2) is unrated with no ceiling membrane.
- Not required when Floor/Ceiling Assembly (Item 2) is 1-hr rated.
- 4. Wall Assembly: 1-hr rated.

Date Revised: August 24, 2023 Page 1 of 1 Spec ID No. 71771