
Pacific Woodtech Corporation
Design No. PWT/RB 60-02
Rim Board
PWT Rim Board
ASTM E119
Rating: 1 -hour



1. **Upper-Level Framing:** Continuous roof/ceiling or floor/ceiling assembly.

2. **Floor/ceiling Assembly:** Unrated.

3. **RIM BOARD**

   CERTIFIED PRODUCT: Pacific Woodtech Corporation. PWT Rim Board

   A. Min. 1-1/4-in. thick PWT Rim Board

   B. Direct-applied protection continuous gypsum wallboard attached to rim board with 1-1/2-in. Type W screws at 12 in. on center (oc):

   - 1/2-in. Type X at occupancy one cavity side is required when Floor/Ceiling Assembly (Item 2) is unrated with gypsum board joints taped and filled.
   - 1/2-in. conventional at each cavity or occupancy sides required when Floor/Ceiling Assembly (Item 2) is unrated with no ceiling membrane.
   - Not required when Floor/Ceiling Assembly (Item 2) is 1-hr rated.

4. **Wall Assembly:** 1-hr rated.