


Pacific Woodtech Corporation
Design No. PWT/RB 60-02
Rim Board
PWT Rim Board
ASTM E119
Rating: 1 -hour



1. Upper-Level Framing: Continuous roof/ceiling or floor/ceiling assembly.

2. Floor/ceiling Assembly: Unrated.

3. RIM BOARD

CERTIFIED PRODUCT: Pacific Woodtech Corporation. PWT Rim Board

A. Min. 1-1/4-in. thick PWT Rim Board

B. Direct-applied protection continuous gypsum wallboard attached to rim board with 1-1/2-in. Type W screws at 12 in. on center (oc):

- 1/2-in. Type X at occupancy one cavity side is required when Floor/Ceiling Assembly (Item 2) is unrated with gypsum board joints taped and filled.

- 1/2-in. conventional at each cavity or occupancy sides required when Floor/Ceiling Assembly (Item 2) is unrated with no ceiling membrane.

- Not required when Floor/Ceiling Assembly (Item 2) is 1-hr rated.

4. Wall Assembly: 1-hr rated.