


Trussbilt Manufacturing Top of Wall Joint Detail

Detail No. T02

Investigated by Intertek for compliance with applicable requirements. For use with Trussbilt's Fire Rated Wall Panel System TBM/MWP 60-01 or TBM/MWP 120-01
For use with 200 plf maximum load on wall.



1. Trussbilt fire rated wall panel TBM/MWP 60-01 (1 hour rating) or TBM/MWP 120-01 (2 hour rating)
2. 12 gauge (minimum) A60 or 409SS channel.
3. Cavity between end of wall panel and trim piece to be filled with concrete or rockwool insulation (4 PCF compressed 50% minimum).
4. 12 gauge (minimum) A60 or 409SS plate secured with 1/4" diameter TEK screws @ 6" O.C. (maximum) top and bottom.
5. 3/4" (minimum) thickness of Hilti Firestop sealant CP606 or Hilti Firestop FS-One sealant.