


Trussbilt Manufacturing Frame Installation Detail

Detail No. F05

Investigated by Intertek for compliance with applicable requirements. For use with Trussbilt's Fire Rated Wall Panel System TBM/MWP 60-01 or TBM/MWP 120-01
For use with load bearing and non-load bearing wall installations.



1. Trussbilt fire rated wall panel TBM/MWP 60-01 (1 hour rating) or TBM/MWP 120-01 (2 hour rating)
2. 12 gauge minimum galv. "Z" channel w/ slotted grout holes. Plug welded in place.
3. 12 gauge fire rated window frame welded to fire rated wall panel per manufacturers instructions. Frame to be grouted. Minimum jamb depth 4-1/2".
4. Minimum 12 gauge glazing stop secured with 1/4" screws 2" max. from ends and 8" max. o.c.

Intertek

Valued Quality. Delivered.