

Product Certification Listing

CERTIFIED BY INTERTEK

PCL – 0506

Issue Date: June 24, 2024

Revision Date: June 24, 2024



Company: CertainTeed LLC
20 Moores Road
Malvern, PA 19355

Wolverine Polypropylene Siding products are molded, polypropylene siding conforming to ASTM D7254, as exterior wall covering

1. LISTING

Listing Ref: Intertek Spec ID: 66955
Category: Polypropylene Siding
CSI Section: 07 46 33 Plastic Siding
Certification Scheme: VSI Product Certification Program
Vinyl Siding Institute, Inc.

Standards: **ASTM D7254-21** Standard Specification for Polypropylene (PP) Siding
NFPA 268-22 Standard Test Method for Determining Ignitability of Exterior Wall Assemblies Using a Radiant Heat Energy Source

2. PRODUCTS

Certified Products and Standard Design Pressure Rating

Brand	Product	Style	Design Pressure (PSF)
Wolverine	Heartwood Pro	Single 7" Shingle Siding ⁽¹⁾	105

1. Standard design pressure rating is the maximum allowable negative wind load when installed horizontally with 1-1/2-inch long, 1/8-inch shank diameter nail with a 7/16-inch head diameter. Spacing shall be 10 inch o.c. for all siding and penetrating into 7/16" min. OSB or plywood.

Additional Properties Evaluated

Property	Test Standard	Rating	Assembly Description
Ignition Resistance	NFPA 268	Meets NFPA 268 acceptance criteria for Radiant Heat Flux of 12.5 kW/m ²	Polypropylene siding installed over 15# asphalt felt water-resistive barrier and 7/16" oriented strand board (OSB).

Product Certification Listing

CERTIFIED BY INTERTEK

PCL – 0506

Issue Date: June 24, 2024

Revision Date: June 24, 2024



Identification: Products covered by this listing are identified with labels that include the following:

CertainTeed LLC
Production lot identification
VSI certification mark
Product Certification Listing (PCL) No, standards and related ratings

Certified By Intertek:

ASTM D7254

Std Design Pressure Rating:

PSF (ASD)



CERTIFICATION PROGRAM

PCL-0506

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name, one of its marks or the VSI mark for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Page 2 of 2

VSI-PCP-PCL: [Month 00, 0000]

1800 Diagonal Road, Suite 545
Alexandria, VA 22314
vinylsiding.org

Intertek
545 E. Algonquin Road
Arlington Heights, IL 60005

