

# Product Certification Listing

CERTIFIED BY INTERTEK

## PCL – 0503

Issue Date: April 18, 2022

Revision Date: January 9, 2025



**Company:** CertainTeed LLC  
20 Moores Road  
Malvern, PA 19355

Cedar Impressions Polymer Shake and Shingle Siding products are molded, polypropylene siding conforming to ASTM D7254, as exterior wall covering.

### 1. LISTING

**Listing Ref:** Intertek Spec ID: 66955  
**Category:** Polypropylene Siding  
**CSI Section:** 07 46 33 Plastic Siding  
**Certification Scheme:** VSI Product Certification Program  
Vinyl Siding Institute, Inc.

**Standards:** **ASTM D7254-21** Standard Specification for Polypropylene (PP) Siding

**NFPA 268-22** Standard Test Method for Determining Ignitability of Exterior Wall Assemblies Using a Radiant Heat Energy Source

### 2. PRODUCTS

#### Certified Products and Standard Design Pressure Rating

Brand	Product	Style	Design Pressure (PSF)
CertainTeed	Cedar Impressions Double 7" Staggered Perfection Shingles 3G	Double 7 (1)	77
	Cedar Impressions Double 7" Straight Edge Perfection Shingles 3G	Double 7 (2)	65
	Cedar Impressions Double 7" Straight Edge Rough-Split Shakes	Double 7 (3)	59
	Cedar Impressions Double 9" Staggered Rough-Split Shakes	Double 9 (3)	37
	Cedar Impressions Individual 5" Sawmill Shingles	Individual 5" (4)	231
	Cedar Impressions Single 6-1/3" Perfection Shapes Half-Cove	Single 6-1/3 (2)	114
	Cedar Impressions Single 6-1/3" Perfection Shapes Octagon	Single 6-1/3 (2)	102
	Cedar Impressions Single 6-1/3" Perfection Shapes Scallop	Single 6-1/3 (2)	117
	Cedar Impressions Single 7" Perfection Shingles	Single 7 (3)	105
	Cedar Impressions Triple 5" Straight Edge Sawmill Shingles	Triple 5 (3)	43

(1) Standard design pressure rating is the maximum allowable negative wind load when installed horizontally with 1-1/2 in. x 0.122 in. Galv. Roofing Nails with 7/16 in. dia. head. Spacing shall be 8 inches o.c. for horizontal siding and penetrating into 7/16 in. min. OSB or plywood with every other nail penetrating wood framing.

(2) Standard design pressure rating is the maximum allowable negative wind load when installed horizontally with 1/8 in. shank diameter, 7/16 in. head, 1-1/2 in. long roofing nails. Spacing shall be 8 inches o.c. for horizontal siding and penetrating into 7/16 in. min. OSB or plywood.

(3) Standard design pressure rating is the maximum allowable negative wind load when installed horizontally with 1-1/2 in. x 0.122 in. Galv. Roofing Nails, with 7/16 in. dia. head. Spacing shall be 10 inches o.c. for horizontal siding and penetrating into 7/16-inch min. OSB or plywood.

(4) Standard design pressure rating is the maximum allowable negative wind load when installed horizontally with 1-1/2 in. long x 7/16 in. crown, 16ga staples. Quantity shall be 2 per shingle for horizontal siding and penetrating into 7/16 in. min. OSB or plywood.

# Product Certification Listing

CERTIFIED BY INTERTEK

## PCL – 0503

Issue Date: April 18, 2022

Revision Date: January 9, 2025



### Additional Properties Evaluated

Property	Test Standard	Rating	Assembly Description
Ignition Resistance	NFPA 268	Meets NFPA 268 acceptance criteria for Radiant Heat Flux of 12.5 kW/m <sup>2</sup>	Polypropylene Siding installed over 15# asphalt felt water-resistive barrier and 7/16" oriented strand board (OSB)

**Identification:** Products covered by this listing are identified with labels that include the following:

CertainTeed, LLC

Production lot identification

VSI certification mark

Product Certification Listing (PCL) No, standards and related ratings

**Certified By Intertek:**

ASTM D7254

Std Design Pressure Rating:

## PSF (ASD)



CERTIFICATION PROGRAM

**PCL-0503**

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name, one of its marks or the VSI mark for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Page 2 of 2

**VSI-PCP-PCL:** [June 21, 2021]

1800 Diagonal Road, Suite 545  
Alexandria, VA 22314  
vinylsiding.org

Intertek  
545 E. Algonquin Road  
Arlington Heights, IL 60005

