

Certificate of Compliance



You have been awarded:

Intertek WH US + C Mark for Category A - Doors - No Additional Edge-sealing System Required

Standards: CAN / ULC S104 (2015) (R2020), UL 10(b) (2008) (R2020), UL 10(c) (2016) Ed. 3 (R:27 May 2021), NFPA 252 (2022)

Certificate number: WHI24 – 7997302

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

Organization:

United Porte INC
8 New Hook Rd
Bayonne, NJ 69028
United States

Product: United Porte INC - 20-90 min Wooden Composite Door SPEC ID 79973

Fire Rating: 20 Min w/Hose Stream PP Cat A Door, 45 Min Neutral Pressure, 60 Min PP Category A Door, 90 Min Neutral Pressure, 30 Min Neutral Pressure, 30 Min PP Category A Door, 90 Min PP Category A Door, 45 Min PP Category A Door, 60 Min Neutral Pressure, 20 Min Neutral Pressure
Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.

Initial registration: August 6, 2024

Date of expiry: December 31, 2026

Issue status: 3

JP Kayl
Vice President – Global Certification
Name

Signature

12/31/25
Date

Registered address:
Intertek Testing Services NA, Inc. 545 E. Algonquin Rd. Arlington Heights, IL 60005 USA

Certificate of Compliance WHI24-7997302

Appendix A

FIRE RESISTANT PRODUCTS & COMPONENTS

CATEGORY A - DOORS - NO ADDITIONAL EDGE-SEALING SYSTEM REQUIRED

PRODUCT DESCRIPTION

Latching Hardware:

Listed Mortise Lock / Cylindrical Lock / Cylindrical with Deadbolt / Card Reader / Surface-Mounted Vertical Rod Fire Exit Devices / Rim-Type Surface Mounted Fire Exit Devices / Mortise Exit Devices / Surface Bolts or Mortised Flush Bolts.

Accessory Hardware:

Surface Mounted Door Bottom / Closer or Overhead Stops.

Temperature Rise Rating: Not Exceed 250°F @ 30 Minutes

Configuration	Maximum Size
Single Swing	- 4'0" wide x 8'0" high

Standard Pairs - Not allowed.

Double Egress - Not allowed.

The product noted above has been tested and qualified per UL 10B, UL10C, NFPA 252 and CAN / ULC S104 for a 90 Minutes Positive Pressure Fire Rating.

This door is eligible for use in any "Category C - Standard" frame. This door may also be installed in frames listed in "Category C - Proprietary" in the accordance with the frame manufacturer's individual listings.

The door noted above is eligible to bear the "S" (for Smoke & Draft Control assemblies) if a listed "Category H - Smoke & Draft Control Gasket" has been applied to the assembly. Please refer to Category H for individual gasket manufacturer's listings.

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing & Certification Ltd and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing & Certification Ltd and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.