

# Certificate of Compliance



You have been awarded:

## **Intertek Warnock Hersey Mark for ACCESS DOOR/FRAME ASSEMBLIES**

Standards: NFPA 288 (2006), NFPA 288 (2021) Ed. 2022

Certificate number: WHI19 - 20178701

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

**Organization: Acudor Products Inc.**

9 Woodland Rd.  
Unit A  
Fairfield, NJ 07068  
United States

**Product: Acudor Products Inc. - 2 Hour Floor Access Door/Frame Assembly  
Spec ID: 48173**

For Maximum Sizes and Ratings See Appendix A (Page 2 of 2)

**Certification body: Intertek Testing Services NA, Inc.**

**Initial registration: March 22, 2019**

**Date of expiry: December 31, 2026**

**Issue status: 4**

JP Kayl

Vice President – Global Certification

Name

Signature

1/28/26

Date

# Certificate of Compliance WHI19 – 20178701

## Appendix A

Product	Trade Names	Rating	Maximum Size	Design Load	Installation In	Standard
Floor Mounted (Horizontal) Aluminum Access Door/Frame Assembly	FRFD/FRFD-R/FRFD-P	120-minute (2-hour)	48" by 48" frame opening dimension	150 psf	Concrete floor/ceiling assembly of minimum 12" thickness	NFPA 288 (2006)
Floor Access Door/Frame Assembly - Oversize	FDO	120-minute (2-hour)	80" by 80" frame opening dimension	300 psf	Concrete floor/ceiling assembly of minimum 12" thickness	NFPA 288 (2021) Ed. 2022*

\* Loading was calculated using frame and overall size of sample.